

कार्यालय नगरपालिका परिषद धार (म. प्र.)

APPENDIX-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. _____ Dated: 10/02/2026
It is certified that an inspection team headed by Renu Verma
(Name of Officers with designation) from S.A.C
(Name of Department/ Office) inspected the SHRI C.K. CHANDEL MEMO.HR.SEC. SCHOOL, DHAR
(M.P.) (Name & Address of the school) on 13.04.26 (date of inspection) and found that the SHRI
C.K. CHANDEL MEMO.HR.SEC. SCHOOL, DHAR (M.P.) (Name of school) has safe drinking water
facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation
condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The
above is valid for a period of 30 years

Signature with Seal: R.V. Singh

Name Designation : R.V. Singh
MO,

Name & Address of the Office / Department : _____

To

MR. RAVI SENGAR, SECRETARY,

SWARGIYA SHRI C.K. CHANDEL SOCITY, CHANDEL BHAWAN MANDU LINK ROAD
DHAR(M.P) 454001

Chief Municipal Officer
Nagar Palika, Dhar (M.P.)

(Name & Address of the Institution) * The filled up certificate should be either in Hindi or English. If it is
issued in vernacular language, translated notarized version in English be uploaded along with the original
vernacular certificate as a single pdf

Chief Municipal Officer
Nagar Palika, Dhar (M.P.)


District Water Testing Laboratory

P.H.E.D. Dhar (M.P.)

Ref. No. dt 29/4/2011

Sample From

Municipal
Shri C.K. Chandel Memorial
W.R. School, Dhar



Analysis Report No. _____

Bill No. _____

Particulars of Sample _____

Date of Collection _____

Date of Receipt 29/4/2011

Date of Analysis 29/4/2011

Description of samples :

- (i) _____
- (ii) Tube well, School Compound
- (iii) _____

S. No.	Parameters	Desirable/Max. Permissible Limit and Unit	Result		
			(i)	(ii)	(iii)
(A)	Physical & Chemical				
1	Colour	5/25 Co.Pt Scale	0		
2	Taste & Odour	Unobjectionable	unobj		
3	Temperature	°C	-		
4	Turbidity	5.0/10 NTU	1.2		
5	pH	7.0 to 8.5/6.5 to 9.2 pH Scale <u>6.5 to 8.5</u>	7.7		
6	Specific Conductivity	Micro mhos/cm	621		
7	Total Dissolved Solids	500/2000 mg/Lit.	400		
8	Total Hardness (as CaCO ₃)	300/600 mg/Lit.	228		
9	Calcium Hardness <u>75/200</u>		64		
10	Magnesium Hardness <u>3/100</u>		15		
11	Sulphate (as SO ₄)	200/400 mg./Lit.	20		
12	Total Alkalinity	mg/Lit. <u>300/600</u>	182		
13	Chlorides (as Cl)	200/1000 mg/Lit.	47		
14	Fluorides (as F)	1.0/1.5 mg/Lit.	0.31		
15	Nitrates (as NO ₃)	45/45 mg/Lit.	8.86		
16	Nitrites (as NO ₂)	Nil	-		
17	Iron (as Fe)	0.1/1.0 mg/Lit.	0		
18	Residual Chlorine	0.2- mg/Lit at Consumer Point.	-		
(B)	Bacteriological				
19	✓ Total Coliform	10 MPN/100 ml	0		
20	✓ Faecal Coliform	Nil	0		

Findings : Water is fit for drinking with in the tested
&
Remark : Parameters

Chemist

Dist. Water Testing Laboratory Dhar

Officer - in - Charge

Public Health Engg. Dn. Dhar

RECEIPT FOR PAYMENTS TO GOVT.

Book No.

831 Receipt No 15

Place ...DLK...

Division

Date ...9.5... 2001

Sub Division

Received from

प्राचार्य श्री के. ए. जन्देश
ममोरियल हा. वी. स्कूल धार

Rs. ...

1000/-

Not Transferable

Rupees

एक हजार मात्र

on account of

जन्म परिशुष 23000

Cashier or Accountant

[Signature]
Assistant Engineer
Designation Sub Division
Public Health
DHAR (M.P.)

Book No 831. 15 Date 9.5.2011

DISTRICT WATER TESTING LABORATORY
P.H.E.D. DHAR.

WATER TESTING CHARGES

Ref.No.

Dated.

To,

The Principal
Dr. C.K. Chandel memorial Hr.-E. School
Dhar

S.No.	Parameters	Rate	No. of tests	Amount
1.	Colour	20.00	1 No	20 = 20
2.	Turbidity	20.00		20 = 20
3.	PH	20.00		20 = 20
4.	Sp. Conductivity	20.00		20 = 20
5.	Total Dissolved solids	20.00		20 = 20
6.	Chloride	50.00		50 = 20
7.	Total Alkalinity	50.00		50 = 20
8.	Total Hardness	50.00		50 = 20
9.	Calcium Hardness	50.00		50 = 20
10.	Magnesium Hardness	50.00		50 = 20
11.	Nitrate	50.00		50 = 20
12.	Iron	100.00		100 = 20
13.	Fluoride	100.00		100 = 20
14.	Total Coliform	200.00		200 = 20
15.	Faecal Coliform	200.00		200 = 20
16.	Collection Charges (with in Dhar)	200.00		
17.	Collection Charges (out of Dhar)	1000.00		

Total = 1000 = 200

CB one time only

[Signature]
Assistant Engineer
P.H.E. Sub Division Dhar

[Signature]